

Change Log

Form:Change Log:06-26

ALTRONIC



Table of Contents

Change Log 1

Change Log

| Release Version | Section | Description |
|-----------------|-----------|---|
| 2.1 | Channels | Low set points should be before high set points (Safety and Control) |
| 2.1 | Dashboard | Need a way to create virtual buttons (On/Off, Manual/Auto) |
| 2.1 | Dashboard | Long labels do not contain themselves to the component bounds and automatically resize. Example, LED box, a long label will go on top the box and overwrite other components. |
| 2.1 | Dashboard | Long labels do not contain themselves to the component bounds and automatically resize. Example, LED box, a long label will go on top the box and overwrite other components. |
| 2.1 | Comms | Modbus registers are all read only, where are all the settings for setpoints and such? WE NEED THIS AS A STANDARD for all control panels. Everything should be configurable via modbus. |
| 2.1 | HMI | Must have a refresh button on the Dashboard and values page so it will reload the channel labels. Currently you must reboot each time to force a reload. |
| 2.1 | Dashboard | Need to be able to Insert a new HMI page between two existing pages. |
| 2.1 | Dashbaord | Sometimes clicking on the delete (trashcan) brings up the channel selector and adds a component instead of just removing the component. |
| 2.1 | Dashbaord | Need ability to set background color of Virtual Channels to show alarm state, faults,etc |

From:

<https://www.staging.altronic.a2hosted.com/> - **wiki STAGING !!!!!**

Permanent link:

<https://www.staging.altronic.a2hosted.com/doku.php?id=documents:de4000:de4000changelog&rev=1643051029>

Last update: **2022/01/28 16:17**